

EDGEFIELD COUNTY  
REQUEST FOR BIDS  
RFB# 11/29/2010

Project Description:

Emergency Management Agency is requesting sealed bids for security fence at Communications tower. The tower is to be located a 35 Star Road, Edgefield, SC, 29824. The fence will enclose tower and transmitter site. Installation is To be completed 5 days after tower erection.

Proposal Date, Time, Location:

Sealed proposal packages must be received no later than 4:30PM EST, On Monday November 29, 2010 at the County Administration Office, 124 Courthouse Square, Edgefield, SC 29824.

Contact:

Mike Casey will be the contact person. He may be reached at 803-480-1116 or [mcaseyksx@bellsouth.net](mailto:mcaseyksx@bellsouth.net). The bid package may be obtained at The Edgefield County Web site [edgefieldcounty.sc.gov](http://edgefieldcounty.sc.gov)

Requirements:

- A. REB # 11/29/2010 must be indicated on outside of bid package
- B. Proof of Workers Compensation and General liability insurance
- C. 3 references required
- D. No faxed bids accepted.

Listed below are specifications for the project. Edgefield County EMA reserves the right to make minor change orders in the field should conditions warrant.

Item #1 is a 60X40 foot enclosure for the tower and transmitter building. The enclosure will be six feet tall (72 inches) with three runs of barbed wire on the top. The fence will have a seven gauge bottom tension wire. The enclosure will have two (2) seven foot gates side by side resulting in a fourteen (14) foot opening.

Item #2 is three (3) security fences, one each at three guy wire anchor points. The fences shall be of triangular shape ten feet at the base with each leg thirty feet. One, three foot gate per enclosure.

Item #3 is three (3) security fences, one each at three guy wire anchor points. The fences shall be of triangular shape ten feet at the base with each leg twenty feet. One three foot gate per enclosure.

ALL CHAIN LINK FABRIC shall be nine (9) Gauge, 72 inch height, GAW material with two inch mesh. Selvage shall be T and T. Bottom tension wire for the 60X40 enclosure shall be 7 gauge. The fences are to be topped with three (3) strands of Class 3 barbed wire.

All ENCLOSURES shall have three inch corners, ends and walk gate posts. Schedule 40 or SS 40. Line posts shall be two inch schedule 40 or SS 40. Top rail, braces, gate frame shall be 1 5/8 inches schedule 40 or SS 40 material.

Brace and truss at all corners.

One (1) hold back for drive gate

Two (2) four inch double gate posts Schedule 40 or SS 40.